



- NOTES:**
1. ALL DIMENSIONS ARE IN MM.
  2. GRADE OF CONCRETE AND CONFORMING TO IS-456:2000.
  3. GRADE OF STEEL IS 115 CONFORMING TO IS-1786:1985.
  4. COVER CONCRETE TO MAIN REINFORCEMENT/STIRRUPS/STIES AS APPLICABLE.
  5. SLAB/WALLS - 25mm
  6. BEAMS - 25mm
  7. COLUMN - 40mm
  8. DEPTH OF THE FOOTING UP TO HARD STRATA MIN DEPTH 1.50M
  9. CENTER LINE DISTANCES ARE APPROXIMATE TO BE CONFIRMED WITH FINAL DRC
  10. FOOTING DESIGNED FOR HARD STRATA TO BE CONFIRMED WITH IRC REPORT

\* JJ  
Expansion Joint